



ENVIRONMENTAL LABORATORIES

SAMPLING ■ ANALYSIS ■ REPORTS ■ CONSULTATION

NYSDOH ELAP 10081
Daniel M. Panek, Director

REPORT OF ANALYSES

STONE GOOSE ENT. INC.
4440 FAIRVILLE MAPLE
RIDGE RD.
NEWARK, NY 14513

DATE: 07/07/22

YOUR REF/P.O.: 0010-L-PAID

SAMPLE NUMBER-	32636	SAMPLE ID-	0622-1517	SAMPLE MATRIX-	WA
DATE SAMPLED-	06/29/22	LOCATION-	CKWT - 5630 NORRIS RD., NORTH ROSE (DRILLED WELL)	TIME SAMPLED-	0830
DATE RECEIVED-	06/29/22	SAMPLER-	RG	RECEIVED BY-	DMP
TIME RECEIVED-	1220	DELIVERED BY-	RG	TYPE SAMPLE-	Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS	DET. LIMIT
COLIFORM - TOTAL	SM18 9222B	06/29/22	1335	DMP	< 1 col./100ml	1

Potable water requires < 1 col. of Total Coliform per 100 ml water as stated in NYS sanitary code. < 1 = Absent.

APPROVED FOR RELEASE

These results relate to only the samples as received at the Laboratory



ENVIRONMENTAL LABORATORIES

SAMPLING ■ ANALYSIS ■ REPORTS ■ CONSULTATION

NYSDOH ELAP 10081
Daniel M. Panek, Director

REPORT OF ANALYSES

STONEGOOSE ENT. INC.
4440 FAIRVILLE MAPLE
RIDGE ROAD
NEWARK, NY 14513

DATE: 06/29/21

YOUR REF/P.O.: 0010-L-PAID

SAMPLE NUMBER-	30965	SAMPLE ID-	0621-1194	SAMPLE MATRIX-	WA
DATE SAMPLED-	06/22/21	LOCATION-	CKWT - 5630 NORRIS RD., NORTH ROSE (DRILLED WELL)	TIME SAMPLED-	0840
DATE RECEIVED-	06/22/21	SAMPLER-	RAG	RECEIVED BY-	DMP
TIME RECEIVED-	0937	DELIVERED BY-	RAG	TYPE SAMPLE-	Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS	DET. LIMIT
COLIFORM - TOTAL	SM18 9222B	06/22/21	1340	DMP	< 1 col./100ml	1

Potable water requires < 1 col. of Total Coliform per 100 ml water as stated in NYS sanitary code. < 1 = Absent.

APPROVED FOR RELEASE

These results relate to only the samples as received at the Laboratory



ENVIRONMENTAL LABORATORIES

SAMPLING ■ ANALYSIS ■ REPORTS ■ CONSULTATION

NYSDOH ELAP 10081
Daniel M. Panek, Director

REPORT OF ANALYSES

STONE GOOSE ENTERPRISES
4440 FAIRVILLE MAPLE
RIDGE ROAD
NEWARK, NY 14513

DATE: 07/01/20

YOUR REF/P.O.: 0010-L-PAID

SAMPLE NUMBER-	29355	SAMPLE ID-	0620-1249	SAMPLE MATRIX-	WA
DATE SAMPLED-	06/24/20	LOCATION-	CKWT - 5630 NORRIS RD., NORTH ROSE (DRILLED WELL)	TIME SAMPLED-	0815
DATE RECEIVED-	06/24/20	SAMPLER-	RAG	RECEIVED BY-	DMP
TIME RECEIVED-	0929	DELIVERED BY-	RAG	TYPE SAMPLE-	Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS	DET. LIMIT
COLIFORM - TOTAL	SM18 9222B	06/24/20	1315	DMP	< 1 col./100ml	1
NITRATE - (AS N)	ORION 1985	06/29/20		DMP	< 0.10 mg/L	0.10

Potable water requires < 1 col. of Total Coliform per 100 ml water as stated in NYS sanitary code. < 1 = Absent.
Maximum Contamination Limit: Nitrate = 10.0 mg/L.

APPROVED FOR RELEASE

These results relate to only the samples as received at the Laboratory



ENVIRONMENTAL LABORATORIES

SAMPLING ■ ANALYSIS ■ REPORTS ■ CONSULTATION

NYSDOH ELAP 10081
Daniel M. Panek, Director

REPORT OF ANALYSES

STONE GOOSE FARMS
4440 FAIRVILLE MAPLE
RIDGE RD.
NEWARK, NY 14513

DATE: 06/19/19

YOUR REF/P.O.: 0010-L-PAID

SAMPLE NUMBER-	27539	SAMPLE ID-	0619-1200	SAMPLE MATRIX-	WA
DATE SAMPLED-	06/13/19	LOCATION-	CKWT - 5630 NORRIS RD., NORTH ROSE (DRILLED WELL)	TIME SAMPLED-	1100
DATE RECEIVED-	06/13/19	SAMPLER-	RAG	RECEIVED BY-	DMP
TIME RECEIVED-	1155	DELIVERED BY-	RAG	TYPE SAMPLE-	Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS	DET. LIMIT
COLIFORM - TOTAL	SM18 9222B	06/13/19	1435	DMP	< 1 col./100ml	1
NITRATE - (AS N)	ORION 1985	06/14/19		DMP	0.11 mg/L	0.10

Potable water requires < 1 col. of Total Coliform per 100 ml water as stated in NYS sanitary code. < 1 = Absent.
Maximum Contamination Limit: Nitrate = 10.0 mg/L.

APPROVED FOR RELEASE

These results relate to only the samples as received at the Laboratory